



June 22, 2018

To: Waverly Elementary School

From: Christopher Madden, CIH
Indoor Environmental Quality Manager

Re: Indoor Air Quality Testing During Renovations - June

As Waverly Elementary School is currently undergoing renovations, the Howard County Public School System's Office of the Environment is conducting weekly Indoor Air Quality (IAQ) Testing to determine if renovation activities are adversely impacting the IAQ in areas located in close proximity to the renovation. The Office of the Environment visited Waverly Elementary on June 1, 8, and 15, 2018. The Office of the Environment observed if engineering controls were in place to limit construction related constituents from migrating into occupied areas of the school and collected measurements of temperature, relative humidity, carbon dioxide (CO₂), carbon monoxide (CO), volatile organic compounds (VOCs), and particulate matter.

General Observations

June 1, 8, and 15, 2018

Construction activities varied during the assessment and included electrical work, duct installation, and finishing work. The construction containments were in place and negative air machines were operational (if work was taking place). In general, interior work was limited during the Office of the Environment's assessments.

Visible emissions were not observed in the school in the vicinity of the construction containment.

General Indoor Air Quality Measurements

Temperature, Relative Humidity, CO₂, CO, and VOC readings were collected as part of the IAQ assessment.

The American Society of Heating Refrigeration and Air Conditioning Engineers (ASHRAE) recommends a temperature range of 68.5 to 75 degrees Fahrenheit (F) in the winter and 75 to 80.5 degrees F in the summer (assuming 50% relative humidity) (Indoor Environmental Quality 2015). The recommended temperature ranges vary slightly depending on relative humidity. There are no recommendations for the spring and fall due to the variabilities in outdoor temperatures.

To prevent mold growth, The Environmental Protection Agency (EPA) recommends relative humidity should be maintained below 60%, ideally between 30-50%. Humidity readings below 30% are often encountered in buildings where humidity is not introduced through the Heating Ventilation and Air Conditioning (HVAC) system.

Carbon Dioxide measurements can provide a general sense of the adequacy of the ventilation system. It is recommended that CO₂ readings be less than 700 parts per million (ppm) plus the outside concentration of CO₂.

Carbon Monoxide can be introduced through incomplete combustion (car exhaust, improperly ventilated boilers, etc.) and should not exceed 9 ppm.

“Low levels of VOCs are ubiquitous in indoor and outdoor air from both natural and man-made sources (The IAQ 2016). VOCs can be introduced by a variety of indoor (paints, perfumes, art products, building materials, carpet, furnisher, etc.) and outdoor sources (vehicles, manufacturing emissions, etc.). A “spike” is identified when indoor readings are significantly higher than the outdoor readings.

Temperature, Relative Humidity, CO₂, and CO data was collected using a TSI IAQ Calc (Model #7545). VOC data was collected using a Rae ToxiRae Pro Photoionization Detector (PID) (Model #PGM-1800). Below are the results of the temperature, relative humidity, CO₂, and CO measurements collected.

Table I - General IAQ Measurements – June 1, 2018

Location	Temperature (F)	Relative Humidity (%)	CO₂ (ppm)	CO (ppm)	Total VOCs (ppm)
Outside	88.9	53.4	518	0.0	0.2
Construction Containment	77.7	32.5	450	0.3	0.0
Lobby	77.9	48.1	688	0.0	0.1
Music	74.5	57.1	686	0.0	0.0
Cafeteria	76.4	57.8	668	0.0	0.1
Hallway Outside of Health Suite	74.0	56.4	622	0.0	0.0
A123	74.0	55.9	615	0.0	0.0
A125	74.1	55.0	550	0.0	0.0
Health	72.9	54.3	767	0.0	0.0
Media	75.3	54.4	846	0.0	0.1
1 st Floor Addition (Near B135)	74.5	59.3	624	0.0	0.0
Outside	80.1	73.9	413	0.0	0.0

Note: Bolded values were not within recommended limits.

Table II - General IAQ Measurements – June 8, 2018

Location	Temperature (F)	Relative Humidity (%)	CO₂ (ppm)	CO (ppm)	Total VOCs (ppm)
Outside	88.3	-	436	0.6	0.1
Construction Containment	81.1	34.4	450	0.0	0.0
Lobby	74.2	54.5	584	0.0	0.1
Cafeteria	74.4	52.2	570	0.0	0.1
Music	74.5	52.8	761	0.0	0.1
Hallway Outside of Health Suite	75.0	52.8	580	0.0	0.0
A124	74.6	51.1	640	0.0	0.0
A125	74.6	50.2	614	0.0	0.0

Table II - General IAQ Measurements (Continued) – June 8, 2018

Location	Temperature (F)	Relative Humidity (%)	CO ₂ (ppm)	CO (ppm)	Total VOCs (ppm)
Conference Room	73.4	53.1	631	0.0	0.1
Media	72.8	52.3	909	0.0	0.0
1 st Floor Addition (Near B135)	74.4	48.0	582	0.0	0.0
Outside	79.8	60.2	416	0.0	0.0

Table III - General IAQ Measurements – June 15, 2018

Location	Temperature (F)	Relative Humidity (%)	CO ₂ (ppm)	CO (ppm)
Outside	81.4	31.6	439	0.0
Construction Containment	78.4	31.8	463	0.1
Lobby	78.9	37.1	636	0.0
Cafeteria	76.6	40.2	685	0.0
Music	76.5	40.9	820	0.0
Hallway Outside of Health Suite	75.4	40.0	539	0.0
A125	75.5	40.3	513	0.0
Health Suite	72.5	41.7	605	0.0
Media	74.0	45.9	593	0.0
1sr Floor Addition	74.3	42.5	558	0.0
Outside	75.6	39.3	373	0.0

Particulate Matter Measurements

Particulate matter “is a complex mixture of extremely small particles and liquid droplets that get into the air (Particulate 2017). The data collected does not distinguish between types of particles in the air which can include pollen, skin cells, soil, human/animal hairs, etc. Particles designated as “respirable” are less than 10 micrometers (μm) in diameter and typically fall into two categories, coarse and fine particles. Coarse particles are those that are less than 10 μm (PM_{10}) and fine particles are those less than 2.5 μm ($\text{PM}_{2.5}$). ANSI/ASHRAE standard 62.1-2016 suggests target indoor concentration for $\text{PM}_{2.5}$ and PM_{10} of 12 and 50 $\mu\text{g}/\text{m}^3$ respectively.

Particulate matter data was collected with a TSI AeroTrak Particle Counter (Model #9306-V2). Note that the particle counter is not capable of collecting $\text{PM}_{2.5}$ data. Due to this limitation, $\text{PM}_{3.0}$ data is used. This would provide a more conservative, overestimate of $\text{PM}_{2.5}$.

Table V - Particulate Matter Measurements – June 1, 2018

Location	PM_{0.5} (μ/m³)	PM_{1.0} (μ/m³)	PM_{3.0} (μ/m³)	PM_{5.0} (μ/m³)	PM_{10.0} (μ/m³)
Outside	2	3	5	12	38
Construction Containment	2	3	5	11	27
Lobby	1	2	4	9	28
Music	1	1	2	5	9
Cafeteria	1	1	2	3	8
Hallway Outside of Health Suite	1	1	2	5	17
Health	1	1	2	5	20
Media	1	1	4	19	66
1 st Floor Addition (Near B135)	1	1	2	3	16
Outside	2	3	4	11	26

Table VI - Particulate Matter Measurements – June 8, 2018

Location	PM_{0.5} (μ/m³)	PM_{1.0} (μ/m³)	PM_{3.0} (μ/m³)	PM_{5.0} (μ/m³)	PM_{10.0} (μ/m³)
Outside	2	3	6	13	27
Construction Containment	2	3	5	8	26
Lobby	1	1	2	5	11
Cafeteria	1	1	2	4	7
Music	1	1	3	8	23
Hallway Outside of Health Suite	1	1	3	9	30
A124	1	1	3	9	27
A125	1	1	3	13	57
Conference Room	2	3	5	9	20
Media	1	1	4	17	73
1 st Floor Addition (Near B135)	1	1	2	4	22
Outside	5	4	7	12	24

Table VII - Particulate Matter Measurements – June 15, 2018

Location	PM_{0.5} (μ/m³)	PM_{1.0} (μ/m³)	PM_{3.0} (μ/m³)	PM_{5.0} (μ/m³)	PM_{10.0} (μ/m³)
Outside	0	0	1	4	14
Construction Containment	0	0	1	3	6
Lobby	0	1	6	20	73
Cafeteria	0	1	7	17	43
Music	0	1	6	21	65
Hallway Outside of Health Suite	1	3	29	98	265
A125	0	1	5	12	56
Health Suite	1	3	25	83	225
Media	0	0	1	3	12
1 st Floor Addition (Near B135)	0	0	1	5	24

Table VII - Particulate Matter Measurements (Continued) – June 15, 2018

Location	PM_{0.5} (µ/m³)	PM_{1.0} (µ/m³)	PM_{3.0} (µ/m³)	PM_{5.0} (µ/m³)	PM_{10.0} (µ/m³)
Outside	0	0	1	4	9

Discussion

Elevated particulate (PM_{2.5} and PM_{10.0}) was detected in various locations. Elevated concentrations are expected and would not necessarily be associated with construction activities. Dust levels are expected to vary overtime based on student and staff activities. It should be noted that on June 15, classes were changing during the sampling period. The increased activity (students moving between classes) likely contributed to the levels of dust detected.

Conclusion

The sampling activities conducted in June indicate measures are being taken to prevent construction odors/VOCs from entering the occupied areas of the school.

Regarding dust, it should be noted that elevated concentrations are expected and may not necessarily be associated with construction activities. Dust levels are expected to vary overtime based on student and staff activities. Additionally, dust levels are far from the enforceable OSHA Occupational Exposure Limit for respirable nuisance dust of 5,000 µg/m³.

Housekeeping practices are also pivotal for dust control. Increased frequency of vacuuming and cleaning could also help reduce dust levels in areas around the construction containment such as the lobby, hallway outside of health, and the health suite. Sticky mats could also be added in areas where trades enter/exit the construction areas through the school. This will likely alleviate the tracking of construction dusts into occupied areas of the school.

The Office of the Environment will be discontinuing monitoring at this time. It is our understanding that the school will be vacated during the summer while additional work is being performed.

It should be noted that the sampling is not being conducted for Occupational Safety and Health Administration (OSHA) compliance, in association with the renovation/construction contractors.

References

Indoor Environmental Quality, the National Institute for Occupational Safety and Health/Centers for Disease Control and Prevention, September 1, 2015. Retrieved from: <https://www.cdc.gov/niosh/topics/indoorenv/temperature.html>

The IAQ Investigator's Guide, 3rd Edition, American Industrial Hygiene Association, Edited by Ellen C. Gunderson, CIH, CSP, 2016.

Particulate Matter (PM) Pollution, Environmental Protection Agency, Last Updated on August 21, 2017. Retrieved from: <https://www.epa.gov/pm-pollution>

Volatile Organic Compounds (VOC) Criteria for New Construction White Paper, American Industrial Hygiene Association, March 15, 2017.